


A

MUELLER THERMAL-COIL METER BOX (3/4" - 1")

Relative Scale 1"=1'
 Absolute Scale 1:12



ISPWC SPECIFICATION REFERENCE
 SEC 404 WATER SERVICE LINE AND METERS

ISPWC IDAHO STANDARDS FOR PUBLIC WORKS CONSTRUCTION

GENERAL NOTES

A ISPWC SD-401 WATER SERVICE CONNECTION (3/4" - 1")

X SHEET KEYNOTES

- 1 18" PIT ADAPTOR
- 2 1" ANGLE VALVE BALL WITH LOCK TAB
- 3 SINGLE ANGLE CHECK VALVE
- 4 1" BRASS NIPPLE MALE IRON PIPE (MIP) THREAD OUTLET CONNECTION
- 5 1" BRASS NIPPLE MALE IRON PIPE (MIP) THREAD INLET CONNECTION
- 6 1" COILED COPPER TUBE SIZE (CTS) TUBING
- 7 16" DIAMETER VAULT ACCESS COVER
- 8 1" UNION
- 9 1" CURB STOP
- 10 REMOVABLE FOAM INSULATOR



CITY OF JEROME PUBLIC WORKS
 Richard Wuori, PE, Director
 152 East Avenue A
 Jerome ID 83338
<http://www.ci.jerome.id.us>

**WATER SERVICE CONNECTION
 3/4" - 1" COIL PIT SETTER**

STANDARD DRAWING NO.

SD-401.1

DATE 15 MAR 2018